

**DISTRICT WATER TESTING LABORATORY, FEROZPUR**

Department of water supply and sanitation, zira gate, circular road, Ferozpur  
dwtfzr@gmail.com

To,

Principal  
Akai Academy VPO-Bharana Tehsil-Zira District-Ferozpur


No.: DWTL/FZR/2526/00266 Dated : 26/02/2026

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. 98 Dated: 23/02/2026

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 25/02/2026. It is request to fill the attached feedback form and send it back to District Water Testing Laboratory, Ferozpur


D/A : Test Report



Authorized Signatory  
For, District Water Testing Laboratory  
Ferozpur



Manager  
Akai Academy Bharana



Principal  
Akai Academy Bharana

**DISTRICT WATER TESTING LABORATORY, FEROZPUR**  
Department of water supply and sanitation, zira gate, circular road, Ferozpur  
dwtfzr@gmail.com



TC-14027

TEST REPORT			
Name & Address of Customer : <b>Principal Akai Academy VPO-Bharana Tehsil-Zira District- Ferozepur</b>		Customer Reference No.	No : 98 Dated : 23/02/2026
		Sample Submitted by	
		Date of Sample Receipt	25/02/2026
		Analysis Starting Date	25/02/2026
		Analysis completion Date	26/02/2026
Discipline : <b>Chemical Testing</b>		Group: <b>Water</b>	
ULR No.:	TC10375260000031F	Sample Type :	Water
Test Report No.:	DWTL/FZR/2526/00266	Date of Issue :	26/02/2026
Registration no.:	DWTL/FZR/REG2526/01605	Condition of Sample :	Sealed
Collection Point:	Private Submersible	Quantity/Type of Bottle:	1000 ml / Plastic Bottles
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	Akai Academy VPO-Bharana Tehsil-Zira District- Ferozepur / NA
Village :	Not Mentioned	Habitation :	Not Mentioned
Block:	Not Mentioned	District :	Ferozepur
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	8.24@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	490	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	0.9	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	T. Alkalinity(CaCO <sub>3</sub> )	248	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	T. Hardness(CaCO <sub>3</sub> )	296	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	104.2	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	8.7	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	30	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected, T=Total)
5. \* Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

*Manju Saini*

Mrs. Manju  
Quality Manager  
Authorized Signatory  
For, District Water Testing Laboratory  
Ferozpur

*Basinder*

Manager  
Akai Academy Bharana

End of the Test Report

*Asheer*

Principal  
Akai Academy Bharana

**SAFE DRINKING WATER & SANITARY CONDITIONS**  
**CERTIFICATE**

No. Fcd/26/117

Dated: 06/04/2026

It is certified that an inspection team headed by Dr Amarveer Singh from O/o Civil Surgeon Ferozepur, District Health officer Ferozepur inspected the Akal Academy Bharana, Village: Bharana, Post Office: Bharana, Tehsil: Zira, District: Ferozepur (Akal Academy VPO- Bharana Tehsil Zira Distt. Ferozepur) on 12/03/26 and found that the Akal Academy Bharana has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the State Govt.

The above is valid for a period of 1 Year from the date of Issuance.

Signature with Seal: .....


Name : Designated Officer  
: O/o Civil Surgeon

Designation : Ferozepur

Name of the Office: Dr. Amarveer Singh



Manager  
Akal Academy Bharana



Principal  
Akal Academy Bharana